

Public Water System Name <i>Village of Dering Harbor</i>	Reporting Month/Y. <i>05/2018</i>	Date Report Submitted <i>04/02/2018</i>	Source Water Type (s) <input type="checkbox"/> Surface <input checked="" type="checkbox"/> Ground <input type="checkbox"/> GWUDI <input type="checkbox"/> Purchase with subsequent chlorination <input type="checkbox"/> Purchase w/out subsequent chlorination
Public Water System ID <i>NY5103700</i>	County <i>Suffolk</i>	Town, Village or City <i>Shelter Island</i>	

DATE	Source(s) in use <i>well #1</i>	Treated water volume (1,000 gallons/day)	Chlorination			Free chlorine residual at entry point (mg/l)	Other Treatments / Readings		
			Gascons Cylinder weight (lbs.)	Chlorine used per day (lbs.)	Liquid Hypochlorite added to crock (gallons or quarts)		<i>Calcium hypochlorite</i>	# Socks	<i>Temperature</i>
1		0				.5		.5	7.24
2		1				.5		.3	7.30
3		0				.5		.3	7.31
4		0				.5		.3	7.29
5		3				.6		.3	7.10
6		2				.6		.3	7.30
7		1				.6		.3	7.10
8		0				.6		.3	7.38
9		2				.6		.3	7.09
10		0				.6		.3	7.10
11		0				.6		.3	7.11
12		0				.6		.3	7.10
13		0				.6		.3	7.10
14		3				.5		.3	7.03
15		5				.5		.3	6.99
16		5				.5		.3	7.01
17		0				0		0	0
18		0				0		0	0
19		0		<i>out of service</i>		0		0	0
20		0				0		0	0
21		0				0		0	0
22		0				0		0	0
23		0				0		0	0
24		0				0		0	0
25		0				0		0	0
26		0				0		0	0
27		0				0		0	0
28		0				0		0	0
29		0				0		0	0
30		0				0		0	0
31		0				0		0	0
TOTAL		39000				0	32#	48	114.55
AVG.		1315				0.6	0	2.00	7.16

Chlorine Mix Ratio: 4 quarts/gallons of 15 % chlorine added to 7 1/2 gallons of water in crock.

Reported by: Harold Bowditch Jr Title: Chief water operator NYSDOH Operator Certification Number: NY0032762

Signature: [Signature] Date: 4/2/18 Operator Grade Level: C

Public Water System Name <i>Village of Dairy Harbor</i>	Reporting Month/Y. <i>03/2018</i>	Date Report Submitted <i>04/22/2018</i>	Source Water Type (s) <input type="checkbox"/> Surface <input checked="" type="checkbox"/> Ground <input type="checkbox"/> GWUDI <input type="checkbox"/> Purchase with subsequent chlorination <input type="checkbox"/> Purchase w/out subsequent chlorination
Public Water System ID <i>NY5103700</i>	County <i>Suffolk</i>	Town, Village or City <i>Shelter Island</i>	

DATE	Source(s) in use <i>251#</i>	Treated water volume (1,000 gallons/day)	Chlorination			Free chlorine residual at entry point (mg/l)	Other Treatments / Readings			
			Gascons Cylinder weight (lbs.)	Chlorine used per day (lbs.)	Liquid Hypochlorite added to crock (gallons or quarts)		Calcium <i>ppm</i>	# Soda <i>ash</i>	Phosphate <i>4/gal</i>	pH
1		3				.6			.3	7.53
2		8				.6			.3	7.56
3		0				.6			.3	7.51
4		3				.6			.3	7.61
5		5				.6			.3	7.61
6		0				.6			.3	7.63
7		0				.6			.3	7.30
8		0				.6			.3	7.45
9		2				.6			.3	7.39
10		2				.6			.3	7.61
11		4				.6			.3	7.65
12		6				.6			.3	7.77
13		4				.6			.3	7.78
14		4				.6			.3	7.80
15		2				.6			.3	7.88
16		2				.6			.3	7.50
17		0				.6			.3	7.37
18		0				.6			.3	7.40
19		5				.6			.3	7.55
20		4				.6			.3	7.48
21		6			8	.6	2		.3	7.30
22		3				.6			.3	7.57
23		5				.5			.3	7.41
24		4				.5			.3	7.44
25		5				.6			.3	7.44
26		6				.6			.3	7.45
27		4				.6			.3	7.43
28		4				.6			.3	7.39
29		8				.6			.3	7.43
30		1				.6		32#	.4	7.45
31		5				.6			.4	7.53
TOTAL		105,000			8		2	32#	9.6	233.90
AVG.		3,387			0.30	0.60	0.000	1.03	0.31	7.53

Chlorine Mix Ratⁿ. 4 quarts/gallons of 15 % chlorine added to 7 1/2 gallons of water in crock.

Reported by: HAP Boudrick Jr Chief Title: Water Operator NYSDOH Operator Certification Number: NY0032762

Signature: [Signature] Date: 4/2/18 Operator Grade Level: C